


NEPAL WATER SUPPLY CORPORATION
BIRGUNJ BRANCH OFFICE



Monthly Report on Chemical Analysis Of Water

S.No.	Date	Name Of Place	Appearance	Turbidity (NTU)	Colour	pH	Temperature (degree)	F.R.C. (Mg/L)	Total Iron (M/L)	Total Ammony (Mg/L)	Chloride (Mg/L)	Coliform	Remk.
1	5/2/2082	ward no-12, Murli-4607	Clear	<5NTU	<5 Hezan	6.5	35	0.2	0.1	0.2	113.68	0	Good
2	5/2/2082	ward no-12, Murli-4619	Clear	<5NTU	<5 Hezan	6.5	35	0.2	0.2	0.2	101.92	0	Good
3	5/2/2082	ward no-12, Murli-4641	Clear	<5NTU	<5 Hezan	7.0	34	0.1	0.2	0.2	94.08	0	Good
4	5/3/2082	Shreepur Pump Station	Clear	<5NTU	<5 Hezan	6.5	33	0.5	0.2	0.2	113.68	0	Good
5	5/3/2082	Padam Road Pump Station	Clear	<5NTU	<5 Hezan	6.5	33	0.5	0.2	0.2	101.92	0	Good
6	5/3/2082	Laxumnawa Pump Station	Clear	<5NTU	<5 Hezan	6.5	33	0.5	0.2	0.2	94.08	0	Good
7	5/3/2082	Adersnager Pump Station	Clear	<5NTU	<5 Hezan	6.5	33	0.5	0.2	0.2	113.68	0	Good
8	5/3/2082	Nagwa Pump Station	Clear	<5NTU	<5 Hezan	7.0	33	0.5	0.2	0.2	101.92	0	Good
9	5/3/2082	Alau Pump Station	Clear	<5NTU	<5 Hezan	6.5	34	0.5	0.2	0.2	113.68	0	Good
10	5/7/2082	Id.no.4034-ward no-12	Clear	<5NTU	<5 Hezan	7.0	33	0.2	0.2	0.2	101.92	0	Good
11	5/7/2082	Id.no.4570-ward no-15	Clear	<5NTU	<5 Hezan	7.5	33	0.1	0.2	0.2	94.08	0	Good
12	5/7/2082	Id.no.10728-ward no-16	Clear	<5NTU	<5 Hezan	6.5	33	0.1	0.2	0.2	117.6	0	Good
13	5/7/2082	Id.no.8714-ward no-16	Clear	<5NTU	<5 Hezan	6.5	33	0.1	0.2	0.2	94.68	0	Good
14	5/7/2082	Janat Ansari ward No-12	Clear	<5NTU	<5 Hezan	7.5	33	0.2	0.2	0.2	113.68	0	Good
15	5/8/2082	Shreepur Pump Station	Clear	<5NTU	<5 Hezan	7.8	30.3	1	0.2	0.2	101.92	0	Good
16	5/8/2082	Haider Ali, Ward no-12	Clear	<5NTU	<5 Hezan	7.7	30.3	0.2	0.2	0.2	94.08	0	Good
17	5/8/2082	Community Tap, ward No-13	Clear	<5NTU	<5 Hezan	7.7	30.3	0.2	0.2	0.2	113.68	0	Good
18	5/8/2082	Mohmad Ali, Ward No-12	Clear	<5NTU	<5 Hezan	8.0	30.3	0.1	0.2	0.2	101.92	0	Good
19	5/8/2082	Dhurba Sah, Ward no-15	Clear	<5NTU	<5 Hezan	7.3	30.3	0.1	0.2	0.2	94.08	0	Good
20	5/8/2082	Birendra Paswan Ward no-08	Clear	<5NTU	<5 Hezan	7.9	30.3	0.2	0.2	0.2	101.92	0	Good
21	5/8/2082	Sekhi Musalam, Ward No-13	Clear	<5NTU	<5 Hezan	7.7	30.3	0.2	0.2	0.2	94.08	0	Good
22	5/9/2082	Shreepur Pump Station	Clear	<5NTU	<5 Hezan	6.5	33	1	0.2	0.2	113.68		Good
23	5/9/2082	Padam Road Pump Station	Clear	<5NTU	<5 Hezan	6.5	33	1	0.2	0.2	101.92		Good
24	5/9/2082	Laxumnawa Pump Station	Clear	<5NTU	<5 Hezan	6.5	33	0.5	0.2	0.2	94.08		Good
25	5/9/2082	Adersnager Pump Station	Clear	<5NTU	<5 Hezan	6.5	33	1	0.2	0.2	113.68		Good
26	5/9/2082	Nagwa Pump Station	Clear	<5NTU	<5 Hezan	7.0	33	1	0.2	0.2	101.92		Good

848.
Prepared By:

Approved By:

कार्यालय प्रमुख